



Test Report

Report No	: L21072801	Size	: 63x508mm
Date	: 2021/07/26	Material	: Coconut shell charcoal
Sample	: 20" carbon filter	Origin	: Taiwan
Model NO	: B-224-14	Quantity	: 6000 PCS

Item		Result	Unit
30 minutes residual chlorine flow : 8L/min total flow: 240 Liter	Before	2.05	ppm
	After	0.03	ppm
	Removal	98.54	%
pH value	Originally	6.49	--
	After 3minutes	9.65	--
	After 30minutes	8.79	--
Weight		715	g
Length		508.12	mm
Differential pressure		0.109	kg/cm ²

Please note :

1. CBC filter element dechlorination effect standard $\geq 95\%$
2. The weight and length are counted by product.
3. The report is responsible for sample test only.

Production Manager	Manager of LAD	Analysis worker
黃士源	江美慧	黃緯綱